

### SCOPE OF ACCREDITATION TO ISO/IEC 17025:2017

### CONSUMERS ENERGY/LABORATORY SERVICES

Laboratory Services 135 West Trail Street Jackson, MI 49201

Merideth Armstrong Phone: 517 788 2218 merideth.armstrong@cmsenergy.com

#### CHEMICAL

Valid To: July 31, 2024 Certificate Number: 1097.05

In recognition of the successful completion of the A2LA evaluation process, accreditation is granted to this laboratory to perform the following chemical tests:

Test Type/Technology:	Test Method:
Acid and Base Number of Petroleum Oil Products by Color Indicator Titration	ASTM D974
Analysis of Dissolved Gases in Electrical Insulating Liquids by Gas Chromatography (Carbon Dioxide, Acetylene, Ethylene, Ethane, Hydrogen, Oxygen, Nitrogen, Methane, Carbon Monoxide)	ASTM D3612
Interfacial Tension of Oil Against Water by the Ring Method	ASTM D971
Sampling of Electrical Insulating Liquids	ASTM D923
Standard Test Method for ASTM Color of Petroleum Products (ASTM Color Scale)	ASTM D1500
Standard Test Method for Dielectric Breakdown Voltage of Insulating Liquids Using Disk Electrodes	ASTM D877
Standard Test Method for Dielectric Breakdown Voltage of Insulating Oils of Petroleum Origin Using VDE Electrodes	ASTM D1816
Water Content in Electrical Insulating Liquids by Coulometric Karl-Fischer Titration	ASTM D1533

h\_



# **Accredited Laboratory**

A2LA has accredited

## **CONSUMERS ENERGY/LABORATORY SERVICES**

Jackson, MI

for technical competence in the field of

### **Chemical Testing**

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 General requirements for the competence of testing and calibration laboratories. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated April 2017).



Presented this 28th day of September 2022.

Vice President, Accreditation Services For the Accreditation Council

Certificate Number 1097.05 Valid to July 31, 2024